



INCORPORATED COUNTY OF LOS ALAMOS

101 Camino Entrada, Building 3
Los Alamos, New Mexico 87544 (505) 663-3507
Procurement Division



September 23, 2024

TO ALL HOLDERS OF SOLICITATION DOCUMENTS FOR:

**Invitation for Bids No. IFB25-15
IFB Name: 8-Unit T-Hangar Construction**

Bids Due: 2:00 p.m. (local), October 3, 2024

Addendum No. 2

This Addendum is hereby made a part of the contract documents and specifications of the above referenced project. All other requirements of the original specification shall remain in effect in their respective order. **Acknowledge receipt of this addendum by inserting its number and date in the proposal form.**

PROPOSAL

1. **REPLACE** the "BID FORM" with the attached "REVISED BID FORM" of Addendum No. TWO (2).

SPECIFICATIONS

2. **REPLACE** Specification M-108-2.23, Paragraph 5 with the following paragraph:

Interior lighting shall be LED and shall be rated at 24,000 lumens at 4K color temperature. Lighting shall be controlled by high bay occupancy sensors and manual switches for each space.

PLANS

SHEET 13A OF 14

3. ADD SHEET 13A – T-HANGAR DETAILS – BID ADDITIVE to the Sheet Set.

ATTACHMENTS:

- Questions and Answers
- Plan Sheet 13A – T-HANGAR DETAILS – BID ADDITIVE
- REVISED BID FORM

END OF ADDENDUM NO. TWO (2)



QUESTIONS AND ANSWERS

QUESTION: If the email option is used to submit the bid proposal, will the Contractor receive confirmation that the email was received on time?

ANSWER: Respondents are requested to follow the instructions in the bid package, under ELECTRONIC SUBMISSION, the instructions state, in part, "It is strongly recommended that second follow up email (without the Bid included or attached) be sent to derrill.rodgers@lacnm.us to confirm the Bid was received."

QUESTION: Was the bid submittal deadline extended?

ANSWER: Yes. Addendum One (1) revised the Invitation to Bid to extend the date for submission of bids until 2:00 p.m. (local time) on October 3, 2024.



POWER DISTRIBUTION RISER DIAGRAM

NTS

NOTES:

1. RESIDUAL SPACES 1 AND 2 AND THE EXTERIOR LIGHTS SHALL BE CONNECTED TO THE SAME METER.
2. LABEL EACH METER TO IDENTIFY THE HANGAR TO WHICH IT IS CONNECTED.
3. THIS WORK TO BE BID AS A LUMP SUM ADDITIVE PRICE FOR "INSTALL 9 UNIT GANG METER".
4. EACH SUBPANEL SHALL BE 100A RATED AND PROVIDED WITH A 60A MCB.
5. EACH SUB-PANEL SHALL PROVIDE A MINIMUM OF 4 SPARE BREAKER POSITIONS AFTER THE INDICATED BREAKERS ARE INSTALLED.
6. CONTRACTOR SHALL PROVIDE A MULTI-SOCKET METER BASE AS SHOWN AND WHICH MEETS THE REQUIREMENTS OF THE LOCAL POWER SUPPLIER. CONTRACTOR SHALL COORDINATE WITH THE POWER SUPPLIER TO PROVIDE A DEVICE SUITABLE TO THE SUPPLIER AND RATED FOR THE INSTALLATION TYPE. INSTALLATION, INCLUDING PROVISIONS FOR THE MAIN DISCONNECT AND GROUNDING, SHALL BE IN ACCORDANCE WITH THE POWER SUPPLIER'S REQUIREMENTS. IN THE EVENT A METER BASE WITH THE EXACT NUMBER OF REQUIRED SOCKETS IS NOT AVAILABLE, CONSULT WITH THE ENGINEER FOR ADDITIONAL GUIDANCE. INSTALLATION OF MULTIPLE BASES OR A BASE WHICH INCLUDES SPARE SOCKETS MAY BE ACCEPTABLE WITH APPROVAL BY THE ENGINEER

NOTE:

THE ELECTRICAL DRAWINGS SHOWN ON THIS SHEET ARE FOR GUIDELINE PURPOSES ONLY. CONTRACTOR SHALL PROVIDE PERMIT ELECTRICAL DRAWINGS WHICH SHALL BE SEALED BY A LICENSED ENGINEER IN THE STATE OF NEW MEXICO AS REQUIRED BY ANY AUTHORITIES HAVING JURISDICTION. REFERENCE IS ALSO DIRECTED TO THE PROJECT SPECIFICATIONS FOR FURTHER PERFORMANCE REQUIREMENTS.

NO.	REVISIONS	BY	APP.	DATE
1	ADDENDUM NO. ONE (1)	MJH	SRH	09/20/24

7804 Pan American East Freeway NE, Suite 4
Albuquerque, New Mexico 87109
phone: (505) 797-4921 • fax: (505) 797-1725
www.deltaairport.com



**DELTA AIRPORT
CONSULTANTS, INC.**



CONSTRUCT T-HANGARS		NMDOT-AD PROJECT NO. LAM-24-02	JOB NO. 23063
T-HANGAR DETAILS - BID ADDITIVE		DRAWN BY: MJH	SHEET 13A OF 14
LOS ALAMOS COUNTY AIRPORT		DESIGNED BY: CAR/ABH	
SCALE: NONE	DATE: SEPTEMBER 2024		

C:\Users\lgandhi\OneDrive\Documents\Projects\2024\T-Hangars\T-Hangars.dwg, L3, 9/20/2024, 2:54:27 PM, lgandhi

REVISED BID FORM

Date: _____

BASE BID

Bid Proposal Summary For All Work Depicted In The Plans And Specifications

ITEM NO.	APPROX. QUANTITY	ITEM WITH UNIT PRICE WRITTEN IN WORDS	UNIT PRICES IN FIGURES	EXTENDED TOTAL
			DOLLARS CENTS	DOLLARS CENTS
1 C-105	1 LS	MOBILIZATION _____ _____ PER LUMP SUM		
2 P-608	1,200 SY	ASPHALT SURFACE TREATMENT _____ _____ PER SQUARE YARD		
3 M-107	600 LF	AVIATION BARRICADES (CONTRACTOR FURNISHED) _____ _____ PER LINEAR FOOT		
4 M-108	1 LS	T-HANGAR MATERIALS (8 UNITS) _____ _____ PER LUMP SUM		
5 M-108	1 LS	T-HANGAR ERECTION (8 UNITS) _____ _____ PER LUMP SUM		
6 M-108	1 LS	T-HANGAR FOUNDATION (8 UNITS) _____ _____ PER LUMP SUM		
7 M-108	1 LS	T-HANGAR ELECTRICAL (8 UNITS) _____ _____ PER LUMP SUM		
8 P-619	1,600 SF	PAINT REMOVAL (95-100% LEVEL) _____ _____ PER SQUARE FOOT		
9 P-620	300 SF	MARKING (PERMANENT YELLOW) _____ _____ PER SQUARE FOOT		
10 P-620	600 SF	MARKING (PERMANENT BLACK) _____ _____ PER SQUARE FOOT		

REVISED BID FORM

BASE BID

Bid Proposal Summary For All Work Depicted In The Plans And Specifications

ITEM NO.	APPROX. QUANTITY	ITEM WITH UNIT PRICE WRITTEN IN WORDS	UNIT PRICES IN FIGURES	EXTENDED TOTAL
			DOLLARS CENTS	DOLLARS CENTS
11 P-620	1 LS	REFLECTIVE MEDIA _____ _____ PER LUMP SUM		
12 D-701	140 LF	18" SMOOTH WALL HDPE PIPE _____ _____ PER LINEAR FOOT		
13 D-751	1 EA	4' x 4' NMDOT DROP INLET JUNCTION BOX _____ _____ PER EACH		
14 36.SP	200 LF	12" TRENCH DRAIN _____ _____ PER LINEAR FOOT		

Total Bid Amount \$ _____

REVISED BID FORM

Date: _____

BID ADDITIVE ONE (1)

Bid Proposal Summary For All Work Depicted In The Plans And Specifications

ITEM NO.	APPROX. QUANTITY	ITEM WITH UNIT PRICE WRITTEN IN WORDS	UNIT PRICES IN FIGURES		EXTENDED TOTAL	
			DOLLARS	CENTS	DOLLARS	CENTS
1 M-108	1 LS	REPLACE ELECTRIC METER WITH 9-UNIT GANG METER <hr style="border: 0.5px solid black;"/> <hr style="border: 0.5px solid black;"/> <div style="text-align: right; font-size: small;">PER LUMP SUM</div>				

Total Bid Amount \$ _____